

CALCUL PRIZA DE PAMANT CU TARUSI VERTICALI LEGATI CU PLATBANDA

DETALII TARUSI VERTICALI

<i>Rezistivitate pamant</i>	<i>Lungime tarus</i>	<i>Tip de teava</i>	<i>Numar de tarusi</i>	<i>Diametru tarus</i>	<i>Adancime ingropare capete tarusi</i>		<i>Adancime plantare platbanda</i>	<i>Latime platbanda</i>	<i>Lungime platbanda</i>	<i>Coeficient de utilizare tarusi verticali</i>	<i>Rezistenta electrod vertical</i>	<i>Rezistenta banda de legatura</i>	<i>Rezistenta priza compusa</i>
$\rho(\Omega m)$	$L(m)$	<i>toli</i>	<i>buc</i>	$d(m)$	$h(m)$	$t(m)$	$h(m)$	$d(m)$	$L(m)$	u	$r_t(\Omega)$	$r_b(\Omega)$	$R_t(\Omega)$
50	3.00	2.00	10.00	0.0508	0.80	2.300	0.800	0.040	90.000	0.800	13.562	1.160	0.78

Intocmit
Ing. Paul Zaharia